



33rd Annual State Construction Conference

March 27th, 2014

Successful Fire Sprinkler Systems

WAKE UP!!!!

What's wrong with this picture?

Picture at Final Inspection

Obvious

Valve shut



Not Obvious

Valve was abandoned in place.

Does not meet NCFC 901.4.4 Appearance of equipment

Tamper switch commonly not wired

How does Fire Department know?

Good question...

Successful Fire Sprinkler Systems

Topics of Discussion

- SCO Guideline revisions
- Common design issues with examples
- New checklist
- Common field inspection errors
- End with good examples



NORTH CAROLINA
DEPARTMENT OF INSURANCE
OSFM
OFFICE OF STATE FIRE MARSHAL
ENGINEERING

FIRE SPRINKLER SYSTEMS
*** INTRODUCTION ***

Purpose

This consensus document is to help assure automatic fire sprinkler systems and standpipes are reliable, maintainable, and have long service life. It was developed with the assistance of sprinkler system designers, manufacturers, and contractors, the Professional Engineers of North Carolina (PENC), the American Council of Engineering Companies (ACEC-NC), the American Fire Sprinkler Association (AFSA), the Society of Fire Protection Engineers (SFPE), and key operations personnel at State agencies and universities. It uses various means to obtain stakeholders input for each revision of these cost-effective sprinkler design criteria.

Applicability

This document is offered for **OPTIONAL** use by State agencies and others, in the public interest. Once the owner or the design professional elects to use the relevant criteria it contains are invoked by being referenced and incorporated into the specification written by the engineer for that project, and are no longer optional. Although originally developed for use on State of NC construction projects, previous editions have been widely used by designers in private sector projects, State agencies and universities, and other jurisdictions outside NC. This document, by itself, does not require a fire sprinkler system in any building. It simply provides a set of criteria that may optionally be used, when a system is to be provided. Also, it does not constitute a complete design specification and must be supplemented with project-specific requirements written by the design professional. See pages 16, 17.

Revisions and Circulation

The North Carolina Department of Insurance (NCDI), Office of State Fire Marshal (OSFM), Engineering Division – State Property Plan Review Section, issues this consensus-based document for optional use by designers in writing their specification. Electronic copies are available via e-mail. We would appreciate your comments, questions, or suggestions for improvement in its content. Contact us at 919-661-5880 x271 or e-mail: dajust@ncdi.net

This document is revised periodically, based on field reports and recommendations from stakeholders in the interest groups listed above. Refer to the Revision Record on page 19 for information on the significant changes made in this issue.

NOTE: Fine print paragraphs introduced by "NOTE:" (like this one) contain helpful explanatory material pertaining to a preceding paragraph. They often provide information to help users of this document to understand its technical content or underlying rationale. Some of them reference important requirements of other applicable standards. All of these fine print paragraphs are included for information only.

BEFORE PRINTING, SEE SPECIAL INSTRUCTIONS ON PAGE 16 1 JANUARY 2008

322 Chapinville Rd - Suite 206, Raleigh, NC 27603-3408 Phone: 919.661.5880 FAX: 919.662.4414

NORTH CAROLINA
DEPARTMENT OF INSURANCE
OSFM
OFFICE OF STATE FIRE MARSHAL
Wayne Goodwin | Commissioner of Insurance
Tim Bradley | Assistant State Fire Marshal

FIRE SPRINKLER AND SUPPRESSION SYSTEMS
*** INTRODUCTION ***

Purpose

This consensus document provides guidance to promote design of automatic fire sprinkler, alternative suppression systems and standpipes that are reliable, maintainable, and have long service life as well as classifying buildings as meeting the "Highly Protected Risk" (HPR) standards for insurability. It was developed with the assistance of sprinkler system designers, manufacturers, and contractors, the Professional Engineers of North Carolina (PENC), the American Council of Engineering Companies (ACEC-NC), the American Fire Sprinkler Association (AFSA), the Society of Fire Protection Engineers (SFPE), and key operations personnel at State agencies and universities. It uses various means to obtain stakeholders input for each revision of these cost-effective sprinkler design criteria.

Applicability

This document is offered for **OPTIONAL** use by State agencies and others, in the public interest. Once the owner or the design professional elects to use the relevant criteria it contains are invoked by being referenced and incorporated into the specification written by the engineer for that project, and are no longer optional. Although originally developed for use on State of NC construction projects, previous editions have been widely used by designers in private sector projects, State agencies and universities, and other jurisdictions outside NC. This document, by itself, does not require a fire sprinkler system or alternative suppression system in any building. It simply provides a set of criteria that may optionally be used, when a system is to be provided. Also, it does not constitute a complete design specification and must be supplemented with project-specific requirements written by the design professional. See pages 16, 17.

Revisions and Circulation

The North Carolina Department of Insurance (NCDI), Office of State Fire Marshal (OSFM), Engineering Division – State Property Code Services Section, issues this consensus-based document for optional use by designers in writing their specification. Electronic copies are available via e-mail. We would appreciate your comments, questions, or suggestions for improvement in its content. Contact us at StatePropertyCode@ncdi.gov

This document is revised periodically, based on field reports and recommendations from stakeholders in the interest groups listed above. Refer to the Revision Record on page 19 for information on the significant changes made in this issue.

NOTE: Fine print paragraphs introduced by "NOTE:" (like this one) contain helpful explanatory material pertaining to a preceding paragraph. They often provide information to help users of this document to understand its technical content or underlying rationale. Some of them reference important requirements of other applicable standards. All of these fine print paragraphs are included for information only.

BEFORE PRINTING, SEE SPECIAL INSTRUCTIONS ON PAGE 21 23 MARCH 2009

322 Chapinville Rd - Suite 206, Raleigh, NC 27603-3408 Phone: 919.661.5880 FAX: 919.662.4414

An Equal Opportunity Employer

STATE OF NORTH CAROLINA
DEPARTMENT OF ADMINISTRATION
STATE CONSTRUCTION OFFICE




FIRE SPRINKLER SYSTEMS
GUIDELINES AND POLICIES

2011

Effective July 1, 2011

STATE OF NORTH CAROLINA
DEPARTMENT OF ADMINISTRATION
STATE CONSTRUCTION OFFICE



WATER BASED
FIRE PROTECTION SYSTEMS
GUIDELINES AND POLICIES

2012

Revised March 23, 2012

STATE OF NORTH CAROLINA
DEPARTMENT OF ADMINISTRATION
STATE CONSTRUCTION OFFICE



WATER BASED
FIRE PROTECTION SYSTEMS
GUIDELINES AND POLICIES

2014

Revised March 27, 2014

New and improved 2014

2014 SCO Guidelines

Changes made to guidelines

- Baseline requirements for fire performance designs
- Backflow preventer requirements
- Dry pipe system requirements
- PDF copy of shop drawings and hydraulic calculations on CD at closeout



2014 SCO Guidelines

Baseline requirements for performance designs

- Sprinkler Design Data Summary, refer to guidelines for all items required.
- Drawing scale
- Piping schematic from PIV to most remote valve
- Backflow preventer location
- Main locations (not thru elevator machine rooms, electrical rooms, etc.)





2014 SCO Guidelines

Baseline requirements for performance designs (cont.)

- Electrical equipment locations with schedule, i.e fire pumps, air compressor, tamper and flow switches
- Hanger details
- Riser location, control valves, check valves

The results of showing this information includes more competitive bids, more accurate design, less change orders.





Multiple building sections

Fire main locations

Detailed sprinkler head schedule

Detailed enlargement plan

- GENERAL NOTES FOR FP-101:
- VERIFY EXISTING CONDITIONS. COORDINATE FF PIPING WITH EXISTING CONCRETES AND BUILDING STRUCTURE.
 - PROVIDE ADEQUATE DRAINS AT ALL LOW POINTS AND WHERE A CHANGE IN PIPING DIRECTION PREVENTS DRAINING FROM THE MAIN DRAIN FOR NFPA 13.
 - LOCATE STANDPIPES AND ARRANGE FIRE HOSE VALVES WITH STAIRS TO BE OUT OF THE PATH OF ESCAPE.
 - OCCUPANCY IS LIGHT HAZARD EXCEPT WHERE OTHERWISE INDICATED.
 - REFER TO ARCHITECTURAL DRAWINGS FOR EXISTING CEILING TYPES AND HEIGHTS.
 - PROVIDE SPRINKLERS IN ALL SPACES IN ACCORDANCE WITH NFPA 13.
 - VALVES CONTROLLING HOSE PIPES TO EXPOSED OR WALL AND CEILING. HOSE PIPES TO CEILING TO CEILING AND WALLS AS POSSIBLE. CONSISTENT WITH NFPA 13 SPRINKLER LOCATION REQUIREMENTS.
 - REFLECTORS OF SIDEWALL SPRINKLERS ARE TO BE NO MORE THAN 4" FROM THE WALL. OTHERS ARE TO BE FROM 4" TO 12" BELOW CEILING AND IN ACCORDANCE WITH LISTING.

- NOTES KEYED TO FP-101:
- FLOOR CONTROL VALVE. SEE DETAIL 6/7P-201.
 - STANDPIPE UP TO FLOOR ABOVE. (ALTERNATE BID 1).
 - WALLS TO RELIEVE WALL WEIGHTS AS PRESIDING.
 - STANDPIPE ISOLATION VALVE/WATERPUMP SWITCH. (ALTERNATE BID 1).
 - 3/4" HOSE CONNECTION. SEE DETAIL 6/7P-201. (ALTERNATE BID 1).
 - 4" UNDERGROUND FIRE PROTECTION PIPING UTILITY CONTROL. (ALTERNATE BID 1).
 - STANDPIPE FROM SUBFLOOR LEVEL AND UP TO FLOOR ABOVE. (ALTERNATE BID 1).
 - SPRINKLER PIPE FROM SUBFLOOR LEVEL AND UP TO FLOOR ABOVE.
 - ADDRESSED FIRE RATED PIPE HOSE VALVE CABINET. LOCATE HOSE VALVE 48" ABOVE FLOOR. (ALTERNATE BID 1).
 - VALVE COVER TO TERMINATE 4" UNDERGROUND FIRE PROTECTION PIPE 12" ABOVE FLOOR. (ALTERNATE BID 1).
 - PROVIDE CORROSION RESISTANT SPRINKLER(S) WITHIN THIS ROOM.
 - PROVIDE DETERMINATE TEMPORARILY RATED SPRINKLERS IN THIS ROOM.
 - HOOP BELT BEAM HOLD PIPE TIGHT TO BOTTOM OF BEAM. (PHYSICAL)
 - ORDINARY HAZARD GROUP 1 OCCUPANCY.
 - PROVIDE 1" AUXILIARY DRAIN WITH GATE VALVE.
 - ROUTE AT CEILING ABOVE LIGHT FIXTURE.
 - NON-INSULATED LISTED PIPE. PIPE COVER AS SPECIFIED. (TYPICAL)
 - WALL PIPE RISER FROM FLOOR ABOVE TO FLOOR BELOW.
 - RESTRICT PIPE PENETRATIONS OF FLOOR IN ACCORDANCE WITH THE 2009 I.C.C. STATE BUILDING CODE. BUILDING CODE 114.1.1.1, EXCEPTION 2.
 - LOCATE STANDPIPE AND FIRE HOSE VALVE OUT OF PATH OF ESCAPE.
 - OFFSET OVER AND DOWN WITH 2-90° ELBOWS.
 - OFFSET OVER AND UP WITH 2-90° ELBOWS.
 - WALLS TO RELIEVE EXISTING WALL WEIGHTS AS PRESIDING.
 - REMOVE EXISTING SPRINKLERS AND ASSOCIATED PIPE, HANDERS, ETC. WITHIN THIS AREA. CAP REMAINING DOMESTIC COLD WATER PIPE.
 - COORDINATE ROUTING OF PIPE AND SPRINKLER LOCATIONS WITH PIPING EXPOSED AT CEILING IN THIS ROOM.

SPRINKLER SCHEDULE & LEGEND

SYMBOL	SPRINKLER DESCRIPTION	ORIFICE	TEMP.	FINISH	K-FACTOR
⊕	WALL MOUNTED SERIES. WASH SPRINKLER. GLOBE RESPONSE OR APPROVED EQUAL BY GLOBE. TITOL. RELIEVE.	1/2"	155F	BRASS	5.6
⊙	WALL MOUNTED SERIES. WASH CEILING. GLOBE RESPONSE OR APPROVED EQUAL BY GLOBE. TITOL. RELIEVE.	1/2"	155F	WHITE	5.6
▶	WALL MOUNTED SERIES. WASH CEILING. GLOBE RESPONSE OR APPROVED EQUAL BY GLOBE. TITOL. RELIEVE.	1/2"	155F	WHITE	5.6
⊕	WALL MOUNTED SERIES. WASH CEILING. GLOBE RESPONSE OR APPROVED EQUAL BY GLOBE. TITOL. RELIEVE.	1/2"	155F	CHROME	5.6
⊙	WALL MOUNTED SERIES. WASH CEILING. GLOBE RESPONSE OR APPROVED EQUAL BY GLOBE. TITOL. RELIEVE.	3/4"	155F	WHITE	8.0
⊕	WALL MOUNTED SERIES. WASH CEILING. GLOBE RESPONSE OR APPROVED EQUAL BY GLOBE. TITOL. RELIEVE.	1/2"	155F	BRASS	5.6
⊙	WALL MOUNTED SERIES. WASH CEILING. GLOBE RESPONSE OR APPROVED EQUAL BY GLOBE. TITOL. RELIEVE.	3/4"	155F	CHROME	8.0
▶	WALL MOUNTED SERIES. WASH CEILING. GLOBE RESPONSE OR APPROVED EQUAL BY GLOBE. TITOL. RELIEVE.	1/2"	155F	WHITE	5.6
⊕	WALL MOUNTED SERIES. WASH CEILING. GLOBE RESPONSE OR APPROVED EQUAL BY GLOBE. TITOL. RELIEVE.	1/2"	155F	BRASS	5.6
▶	WALL MOUNTED SERIES. WASH CEILING. GLOBE RESPONSE OR APPROVED EQUAL BY GLOBE. TITOL. RELIEVE.	1/2"	155F	CHROME	5.6
⊕	WALL MOUNTED SERIES. WASH CEILING. GLOBE RESPONSE OR APPROVED EQUAL BY GLOBE. TITOL. RELIEVE.	1/2"	155F	CHROME	5.6
⊙	WALL MOUNTED SERIES. WASH CEILING. GLOBE RESPONSE OR APPROVED EQUAL BY GLOBE. TITOL. RELIEVE.	1/2"	155F	CHROME	5.6
▶	WALL MOUNTED SERIES. WASH CEILING. GLOBE RESPONSE OR APPROVED EQUAL BY GLOBE. TITOL. RELIEVE.	1/2"	155F	CHROME	5.6



FIRST FLOOR - FIRE PROTECTION

FP-101

2014 SCO Guidelines

Backflow preventer requirements

- NCFC 912.5 refers to NCPC for backflow requirements. NCPC Section 608.16.4 requires backflow protection for fire sprinkler systems. Could be DDCV or RPDA type.
- Per NC DENR "TITLE 15A" Minimum backflow preventer for fire protection systems with fire pump, chemicals used or buildings with 5 or more stories above ground is RPDA. (2012)
- The previous requirement included if building had FDC connection RPDA type backflow was required. (2010)

2014 SCO Guidelines

FIGURE 2 NORTH CAROLINA GUIDELINES CROSS CONNECTION CONTROL IN WATER DISTRIBUTION SYSTEMS

These guidelines are supplemental to Section .0406(b). These guidelines are intended as a minimum requirement. Public water suppliers may adopt more stringent requirements. Each supplier of water shall conform to the minimum requirements established in these guidelines.

I. Degree of Hazard:

- A. Severe: Actual or potential threat of contamination that presents an imminent danger to the public health with consequence of serious illness or death.
- B. Moderate: One that presents foreseeable and significant potential for pollution, nuisance, aesthetically objectionable or other undesirable alterations of the drinking water supply.

II. Backflow Prevention Assembly Requirements:

Degree of hazard	RPZ*	DCVA**	Air Gap
Severe	X	-----	X
Moderate	-----	X	-----

- * Reduced pressure zone
- ** Double check valve assembly
- *** This is not intended to be an exhaustive list

III. Facilities that Require Installation of a Backflow Preventer***:

A. Moderate hazard - DCVA:

1. Fire sprinkler systems without booster pump facilities or chemical additives.
2. Connection to tanks, lines and vessels that handle non-toxic substances.
3. Lawn sprinkler systems without chemical injection or booster pumps.
4. Most commercial establishments.
5. Automatic service stations, bakeries and beauty shops with no health hazard and bottling plants with no back pressure.
6. etc.

B. Severe hazard - RPZ or air gap:


1. Lawn sprinkler systems with chemical injection or booster pump
2. Wastewater treatment plants
3. Connection to an unapproved water system or unapproved auxiliary water supply
4. Connection to tanks, pumps, lines, steam boilers or vessels that handle sewage, lethal substances, toxic or radioactive substances
5. Fire sprinkler systems with booster pump facilities or chemical additives
6. Buildings with five or more stories above ground level

2014 SCO Guidelines

Backflow preventer requirements

- Backflow preventer **SHOULD** be installed in a heated enclosure **OUTSIDE**.
- If backflow preventer is installed inside provide emergency drainage to exterior capable of full flow. Could potentially be 500-800 GPM.





Can a 4" floor drain handle
500 GPM? NO!!!!!!!!!!!!!!!!!!!!!!

This is 250 GPM

2014 SCO Guidelines

Dry pipe system requirements

- Black steel piping can be used unless required by NFPA 13 to be galvanized.
- Air dryer recommended for large system
- Nitrogen systems recommended for ultimate protection

2014 SCO Guidelines



Compressor
with air dryer

\$10,000



Nitrogen generator
for large systems with
separate tank

\$30,000



Nitrogen generator
with tank

2014 SCO Guidelines

Group I Occupancy Classifications

- Fire protection zones shall match fire alarm zones.
- Designer shall coordinate with owner to discuss zone locations, egress paths and “defend in place” strategies.




2014 SCO Guidelines

Changes not made to guidelines

- Safety factor consist of 10 psi less static, residual and 10% flow
- Hazard classification is per NFPA 13
- Flow test required within 12 months throughout phases of project.



Common Design Issues



Common Design Issues

- Coordinate with other trades. Electrical demands, site, mechanical equipment, etc.
- Understand site location, i.e elevation changes
- Do not oversize fire pump. Bigger is not better. Example coming up.






clearly specified

Common Design Issues

Hose Coverage – Site

- All portions of building must be within 150' of apparatus road surface.
- Distance must be measured as the hose lays.
- FDC shall be within 100' from fire hydrant.

Common Design Issues



Hose Coverage Details

Common Design Issues




Fire Department Access


NCFC 503

- 20' wide
- Vertical clearance of not less than 13 feet 6 inches
- Greater than 150' requires turn around
- Constructed of all-weather surface
- Must support fire truck, typically 75,000 lbs
- All plans to be reviewed by local Fire Marshal.


Common Design Issues





96' DIAMETER
CUL-DE-SAC



60' "Y"




MINIMUM CLEARANCE
AROUND A FIRE
HYDRANT



Examples of turn arounds from NCFC Appendix D



Common Design Issues



- Include a water flow test per NFPA 13 (using two hydrants) will be required for every project within 12 months throughout design phases.
- Some local authorities flow one hydrant to test flows throughout system. This shall not be used for hydraulic calculations.

Common Design Issues

- High rise buildings shall have at least two remotely located fire department connections for each zone. NFPA 14 7.12.2.
- Previous code required secondary water supply for high rise if seismic was required per section 903.3.5.2. (New buildings).
- Current code requires secondary water supply for high rise with fire pump regardless of seismic per section 914.3.1.2. (New or existing buildings.)



Common Design Issues

Dry pipe systems

- For large dry pipe system with accelerators use air compressor with storage tank.
- Base mounted compressors will not keep up in large systems with huge temperature fluctuations causing accelerators to trip.



Common Design Issues


Dry pipe systems (cont.)

- Try to keep dry pipe systems less than 500 gallons due to required delivery times per NFPA 13-7.2.3.6 and NCFC 903.2.6.1. Group I 60 seconds maximum. SCO does not have maximum since 2009.
- All pipe shall be sloped. Branchlines $\frac{1}{2}$ " per 10', Mains $\frac{1}{4}$ " per 10' **MINIMUM**.



Common Design Issues

- Be aware of site location in reference to sprinkler system. Western areas tend to have massive pressure spikes. SCO recommends pressure relief valves on these systems.
- Get updated flow test during design phase. City supply changes all the time due to expansion. In the past a flow test has found errors with closed valves due to new construction.



Common Design Issues

- Piping plan not going back to source. Where was flow test taken? Two miles down road?
- The source can be a test hydrant, fire pump or PRV valve. The water supply test dates apply to these as well.





Common Design Issues

- Fire pump shall only be sized at pressure needed at required GPM.
- Oversizing fire pumps could result in change order due to not enough municipal GPM. Oversizing pump also cost project \$ up front. Example coming up.




Common Design Issues

- Pressure loss due to devices. Backflow, PRV, Low suction control valve, etc. not accounted for.
- Pressure losses vary with GPM.



Common Design Issues

- Piping plan does not match hydraulic calculations. The hydraulic calculations show 3" but the plans show 2".
- Velocities exceed component ratings. Typical flow switch is 18 ft/sec.
- Actual head coverage in remote area does not match entire building.



$$A = S \times L$$


$S = (5'-0'' \times 2)$ or $10'-0$ (whichever is greater)

$L = (6'-6'' \times 2)$ or $13'-0$ (whichever is greater)


$$S = 10' \quad L = 13'$$

$$A = 13' \times 10'$$

$$A = 130 \text{ sq. ft.}$$




SPRINKLER HEAD AREA OF COVERAGE



WHAT IS SPRINKLER COVERAGE?


180 SF

7'-6" x 2 = 15 x 12



Common Design Issues

- Plans scaled incorrectly
- The design is not printed on the intended page size.
- SCO requires graphical scale.




Common Design Issues

Forward flow testing


NFPA 13, 2007 edition

10.10.2.5 Backflow Prevention Assemblies. [24:10.10.2.5]





NFPA 25, 2008 edition

13.6.2 Testing.
13.6.2.1*



Minimum flow rate is system demand and hose stream where applicable.

Common Design Issues



Common Design Issues

- Response Time Index (RTI) of sprinkler heads in same compartment shall be the same. NFPA 13-2007 8.3.3. Cannot mix standard and quick response in same compartment.
- Compartment can be same room with 8" deep lintel depth maximum 8' wide opening.



Common Design Issues

Fire pump sizing

- A fire pump can only be accurately sized by hydraulic calculations. Do not use “rule of thumbs”.
- Capacity of fire pump is determined by (flow requirements of system provided by hydraulic calculations). This could be sprinkler or standpipes.
- Buildings not classified as high rise that have standpipes are not required to be automatic. Automatic standpipes could increase fire pump size.
- Fire pumps **cannot** create water (flow).

Common Design Issues

Get out calculators



Common Design Issues

Over sizing fire pump – 2 story building

Scenario #1

Flow test at DD phase

56 Static, 51 residual, 719 gpm

Flow test at shop drawing phase

56 Static, 27 residual, 571 gpm

Notice significant drop in residual pressure and flow

Designer specified 750 GPM pump to satisfy standpipe

Pressure available at pump rating (750 GPM) = 8 psi

Available pressure – (Friction loss + backflow loss) = **-1 psi remaining pressure**

Remember previous slide, not required for low rise buildings

This scenario could possibly result in not enough water for fire pump and outside hose for fire fighters!!

Common Design Issues

Over sizing fire pump

Scenario #2

Revise pump selection to 500 GPM to **satisfy sprinkler demand.**

Use city fire pump truck as standpipe supply.

Pressure available at pump rating (500 GPM) = 33 psi

Available pressure – (Friction loss + backflow loss) = **+24.9 psi**

remaining pressure

Common Design Issues

Conclusion

Scenario #1

750 GPM pump (automatic standpipe)

-.1 psi remaining

Scenario #2

500 GPM pump (sprinkler system demand only)


+24.9 psi remaining

**\$30,000
CHANGE ORDER**

Lesson Learned

Designer to take time to understand system demand and available supply. Just remember you can make pressure but you cannot make water.

New Checklists



New Checklists

Fire pump checklist

- SCO required to witness fire pump test
- NFPA 20 test still required. SCO witness can coincide with NFPA 20 test. (This is preferred)
- Includes electric and diesel.
- Checklist will be available on SCO website.

Clean agent checklist

- Generic due to different types of clean agents.
- Checklist will be available on SCO website.



Checklists are for designer and contractor use. Not required to be used.

Please contact me if you see errors or revisions

New Checklists

ELECTRIC/DIESEL FIRE PUMP CHECK LIST



BUILDING NAME: _____ LOCATION: _____

DESIGNER: _____ INSTALLER: _____

SCO REPRESENTATIVE: _____ DATE: _____

PUMP MANUF.: _____ OWNER NAME: _____

INSTALLATION

- Certificate for flushing and hydrostatic test furnished
- Piping been hydrostatically tested at 200 psi or 50 psi above maximum system pressure whichever is greater
- Electric wiring including control wiring, emergency supply been checked by electrical contractor
- Indoor fire pump units separated from all other areas of building by 2-hour rated construction, 1-hour if protected by sprinkler system
- If fire pump unit is located outdoors or if fire pump installation is in a building other than that building being protected by the fire pump, it is located at least 50 feet away from the protected building
- A suitable means for maintaining 40 degrees ambient temperature provided; 70 degrees if driver is diesel engine
- Was a copy of the manufacturer's certified pump test curve available for comparison to the results of the acceptance test?
- Pump room/house provided with normal lighting and emergency lighting
- Pump room/house adequately ventilated and floor is pitched toward drain
- Horizontal pump/driver on common base plate and connected by a listed flexible coupling
- Guard provided for flexible couplings and flexible connecting shafts
- Baseplate securely attached to concrete foundation

New Checklists

CLEAN AGENT SYSTEM CHECK LIST



BUILDING NAME: _____ LOCATION: _____

DESIGNER: _____ INSTALLER: _____

SCO REPRESENTATIVE: _____ DATE: _____


FIRE ALARM TECHNICIAN: _____ OWNER NAME: _____

INSTALLATION

- Are all openings sealed or equipped with automatic closures?
- Other than the ventilation systems identified in 5.3.5.2, forced air ventilation systems all mechanical units shall be shut down or closed automatically where their continued operation would adversely affect the performance of the fire extinguishing system.
- An approved job site copy of plans must be on the site at the time of the inspection in labeled PVC tube.
- Suitable safeguards shall be provided to ensure prompt evacuation of and prevent entry into hazardous atmosphere. i.e. Personnel training, warning signs, discharge alarms.
- Verify storage containers are located as indicated on shop drawings.
- Agent storage shall not be located where it can be rendered inoperable or unreliable due to mechanical damage, exposure to chemicals, harsh weather or any other foreseeable cause.
- If container is connected to a manifold, automatic means, such as a check valve shall be provided to prevent agent loss and to ensure personnel safety
- Each agent container shall have a permanent nameplate or other marking that indicates the following
 - For halocarbons: the agent, gross weights, and super pressurization level of the container.
 - For inert gases: the agent, pressurization level of the container, and nominal agent volume.
- Room pressurization test been performed "door fan test"? Typical minimum retention time is 8-10 minutes.
- O&M manuals been provided to owner

New Checklists

DIESEL FIRE PUMP




KEY NOTES

- ① FIRE PUMP DIESEL ENGINE
- ② MUFFLER
- ③ FIRE PUMP
- ④ JOCKEY PUMP
- ⑤ AIR RELEASE VALVE
- ⑥ AUTOMATIC BALL DRIP VALVE
- ⑦ PUMP TEST HEADER. SIZE AS REQUIRED BY NFPA 20
- ⑧ PROVIDE MINIMUM DISTANCES AS REQUIRED BY FLOW METER MANUFACTURER.
- ⑨ ECCENTRIC REDUCER
- ⑩ CONCENTRIC REDUCER
- ⑪ SUCTION PRESSURE CONTROL VALVE
- ⑫ PRESSURE RELIEF VALVE
- ⑬ CLOSED DISCHARGE CONE WITH SITE GLASS
- ⑭ PIPE FULL SIZE DISCHARGE TO OUTSIDE TO CONCRETE SPLASH BLOCK
- ⑮ PRESSURE GAUGE WITH GAUGE COCK.
- ⑯ PRESSURE SENSING PIPE
- ⑰ COMPOUND PRESSURE VACUUM GAUGE WITH GAUGE COCK.
- ⑱ GLOBE VALVE
- ⑲ DRAIN
- ⑳ PLUG
- ㉑ UNION WITH NONCORROSIVE DIAGRAMS DRILLED FOR 3/4" ORifice
- ㉒ FIRE DEPARTMENT CONNECTION
- ㉓ MINIMUM 10 PIPE DIAMETERS

Diesel fire pump piping schematic


New Checklists

ELECTRIC FIRE PUMP



Electric fire pump piping schematic

Common Field Inspection Issues



Common Field Inspection Issues



Minimum 36" clear space maintained
NCFC 507.5.5

Common Field Inspection Issues

Who was first?



- NCFC 912.3.2 Working space around FDC not less than 36" in width, 36" in depth and 78" in height

Common Field Inspection Issues



Clearance at
FDC and PIV

Common Field Inspection Issues




NFPA 13 2007- 8.16.1.3.1




- A post indicator valve (PIV) shall be located 40 feet from building walls.


No FA connection for the tamper switch.



Wireless???

Where's the heat?





Handles were removed
At testing and never re-
Installed therefore leaving
valve closed,

Reason for not using locks or chains in lieu of tamper switch

Common Field Inspection Issues

- Hangers not installed per NFPA 13 or engineers specifications.
- Sprinkler head spacing around obstructions and heat sources.
- Dry pipe system not properly sloped.
- Dry pipe system not properly sloped.
- Dry pipe system not properly sloped.
Get the hint!!!



Common Field Inspection Issues

- Seismic not installed per NFPA or shop drawings. Brace angles do not match calculations, cables loose, missing braces.
- Sprinkler heads in walk in coolers with automatic defrost shall be intermediate temperature or higher. Any color other than orange or red.
- NFPA forms on final not filled out correctly.
- Missing information on forms.



Common Field Inspection Issues

Contractor's Material and Test Certificate for Aboveground Piping							
PROCEDURE Upon completion of work, inspection and tests shall be made by the contractor's representative and witnessed by the property owner or their authorized agent. All defects shall be corrected and system left in service before contractor's personnel finally leave the job.							
A certificate shall be filled out and signed by both representatives. Copies shall be prepared for approving authorities, owners, and contractor. It is understood the owner's representative's signature in no way prejudices any claim against contractor for faulty material, poor workmanship, or failure to comply with approving authority's requirements or local ordinances.							
Property name			Date				
Property address							
Accepted by approving authorities (names)							
Address							
Plans	Installation conforms to accepted plans			<input type="checkbox"/> Yes	<input type="checkbox"/> No		
	Equipment used is approved			<input type="checkbox"/> Yes	<input type="checkbox"/> No		
If no, explain deviations							
Instructions	Has person in charge of fire equipment been instructed as to location of control valves and care and maintenance of this new equipment?			<input type="checkbox"/> Yes	<input type="checkbox"/> No		
	If no, explain						
Have copies of the following been left on the premises?	1. System components instructions			<input type="checkbox"/> Yes	<input type="checkbox"/> No		
	2. Care and maintenance instructions			<input type="checkbox"/> Yes	<input type="checkbox"/> No		
3. NFPA 25			<input type="checkbox"/> Yes	<input type="checkbox"/> No			
Location of system	Supplies buildings						
Sprinklers	Make	Model	Year of manufacture	Orifice size	Quantity	Temperature rating	
Pipe and fittings	Type of pipe		Type of fittings				
Alarm valve or flow indicator	Type	Alarm device	Make	Model	Maximum time to operate through test connection		
					Minutes	Seconds	
Dry pipe operating test	Dry valve			Q. O. D.			
	Make	Model	Serial no.	Make	Model	Serial no.	
	Time to trip through test connection ^{a,b}		Water pressure	Air pressure	Trip point air pressure	Time water reached test outlet ^{a,b}	
	Minutes	Seconds	psi	psi	psi	Minutes	Seconds
Alarm operated properly							
Yes		No					
If no, explain							

Deluge and preaction valves	Operation <input type="checkbox"/> Pneumatic <input type="checkbox"/> Electric <input type="checkbox"/> Hydraulics						
	Piping supervised <input type="checkbox"/> Yes <input type="checkbox"/> No			Detecting media supervised <input type="checkbox"/> Yes <input type="checkbox"/> No			
	Does valve operate from the manual trip, remote, or both <input type="checkbox"/> Yes <input type="checkbox"/> No						
	Is there an accessible facility in each circuit for testing? <input type="checkbox"/> Yes <input type="checkbox"/> No						
Pressure reducing valve test	Location and floor	Make and model	Setting	Static pressure		Residual pressure (flowing)	
				Inlet (psi)	Outlet (psi)	Inlet (psi)	Outlet (psi)
	Maximum time to operate release				Flow rate		
	Minutes		Seconds		Flow (gpm)		
Test description	Hydrostatic: Hydrostatic tests shall be made at not less than 200 psi (13.6 bar) for 2 hours or 50 psi (3.4 bar) above static pressure in excess of 150 psi (10.2 bar) for 2 hours. Differential dry-pipe valve clappers shall be left open during the test to prevent damage. All aboveground piping leakage shall be stopped.						
	Pneumatic: Establish 40 psi (2.7 bar) air pressure and measure drop, which shall not exceed 1½ psi (0.1 bar) in 24 hours. Test pressure tanks at normal water level and air pressure and measure air pressure drop, which shall not exceed 1½ psi (0.1 bar) in 24 hours.						
Tests	All piping hydrostatically tested at _____ psi (____ bar) for _____ hours			If no, state reason			
	Dry piping pneumatically tested <input type="checkbox"/> Yes <input type="checkbox"/> No						
	Equipment operates properly <input type="checkbox"/> Yes <input type="checkbox"/> No						
	Do you certify as the sprinkler contractor that additives and corrosive chemicals, sodium silicate or derivatives of sodium silicate, brine, or other corrosive chemicals were not used for testing systems or stopping leaks? <input type="checkbox"/> Yes <input type="checkbox"/> No						
Blank testing gaskets	Drain test		Reading of gauge located near water supply test connection: _____ psi (____ bar)		Residual pressure with valve in test connection open wide: _____ psi (____ bar)		
	Underground risers and lead-in connections to system risers flushed before connection made to sprinkler piping <input type="checkbox"/> Yes <input type="checkbox"/> No Other Explain						
	Verified by copy of the Contractor's Material and Test Certificate for Underground Sprinkler Piping <input type="checkbox"/> Yes <input type="checkbox"/> No						
	Flushed by installer of underground sprinkler piping <input type="checkbox"/> Yes <input type="checkbox"/> No						
If powder-driven fasteners are used in concrete, has representative sample testing been satisfactorily completed? <input type="checkbox"/> Yes <input type="checkbox"/> No If no, explain							
Welding	Number used		Locations		Number removed		
	Welding piping <input type="checkbox"/> Yes <input type="checkbox"/> No						
If yes ...							
Do you certify as the sprinkler contractor that welding procedures used complied with the minimum requirements of AWS B2.1, ASME Section IX Welding and Brazing Qualifications, or other applicable qualification standard as required by the AHJ? <input type="checkbox"/> Yes <input type="checkbox"/> No							
Do you certify that all welding was performed by welders or welding operators qualified in accordance with the minimum requirements of AWS B2.1, ASME Section IX Welding and Brazing Qualifications, or other applicable qualification standard as required by the AHJ? <input type="checkbox"/> Yes <input type="checkbox"/> No							
Do you certify that the welding was conducted in compliance with a documented quality control procedure to ensure that (1) all discs are retrieved; (2) that openings in piping are smooth, that slag and other welding residue are removed; (3) the internal diameters of piping are not penetrated; (4) completed welds are free from cracks, incomplete fusion, surface porosity greater than 1/8 in. diameter, undercut deeper than the lesser of 25% of the wall thickness or 3/8 in.; and (5) completed circumferential butt weld reinforcement does not exceed 3/8 in.? <input type="checkbox"/> Yes <input type="checkbox"/> No							

Common Field Inspection Issues

Outouts (discs)	Do you certify that you have a control feature to ensure that all outouts (discs) are retrieved? <input type="checkbox"/> Yes <input type="checkbox"/> No		
Hydraulic data nameplate	Nameplate provided <input type="checkbox"/> Yes <input type="checkbox"/> No	If no, explain	
Remarks	Date left in service with all control valves open		
	Name of sprinkler contractor		
Signatures	Tests witnessed by		
	The property owner or their authorized agent (signed)	Title	Date
	For sprinkler contractor (signed)	Title	Date
Additional explanations and notes			

© 2006 National Fire Protection Association

NFPA 13 (p. 3 of 3)

Common Field Inspection Issues

Dry pipe systems

- Breaking news!!!! Water freezes at 32 degrees.
- Verify unit heaters in riser rooms work.
- Do not shut off unit heaters to save energy.
- If multiple auxiliary drains are used in dry pipe system make accessible and create maintenance plan for routine drainage.



Common Field Inspection Issues




- Dry pipe system not sloped properly
- Piping shown is less than 2 years old




Dry pipe systems

Common Field Inspection Issues

Dry pendent installed in bottom of pipe.
This can cause metal seal to deform
from freezing resulting in leaking.



Trapped
water




Cause

Effect

Common Field Inspection Issues



Not an approved
branch line restraint



Cable around other
trades

Minimum crimps
for different cables



Seismic bracing

Common Field Inspection Issues

Restraints shall extend to structure



Cables shall be tight

Seismic bracing

Common Field Inspection Issues


Flexible couplings
required within 12"
on both sides. NFPA 13
9.3.2.3 (there are exceptions)

Four-way brace missing
NFPA 13 9.3.5.5



Common Field Inspection Issues

Refer to listing of pipe for maximum pipe bends



PERMITTED

NOT PERMITTED

NOT PERMITTED

Water has to drain back to branchline or sprinkler head

Significant friction loss

TABLE 2A: FRICTION LOSS DATA FOR FM WITH 12" (305 mm) MINIMUM BEND RADIUS (1/2" OUTLET)

Part Numbers	Outlet Type	Hose Length with Fittings	Equivalent Length of FM 1" Schedule 40 Pipe (ft.)	Equivalent Length of FM 1" Schedule 40 Pipe (meters)	Maximum Number of 90° Bends Allowed
14350-10	1/2" Straight or 90° Angle	39-3/8**	18.2 ft	5.5 m	1
14350-15		59**	27.1 ft	8.2 m	2



* Indicates standard Viking offering. Other hose lengths are available-contact Viking Technical Services at 877-384-5464 for friction loss data.

TABLE 2B: FRICTION LOSS DATA FOR FM WITH 12" (305 mm) MINIMUM BEND RADIUS (3/4" OUTLET)

Part Numbers	Outlet Type	Hose Length with Fittings	Equivalent Length of FM 1" Schedule 40 Pipe (ft.)	Equivalent Length of FM 1" Schedule 40 Pipe (meters)	Maximum Number of 90° Bends Allowed
14351-10	3/4" Straight or 90° Angle	39-3/8**	15.5 ft	4.7 m	1
14351-15		59**	24.8 ft	7.6 m	2

* Indicates standard Viking offering. Other hose lengths are available-contact Viking Technical Services at 877-384-5464 for friction loss data.

Braided outer jacket required by SCO






Could be 200-500 gpm depending on pressure

Common Field Inspection Issues

Nail in pipe



Provide nail protection via nail plates



CPVC is a good product to use, however there are a number of restrictions the designer should keep in mind. Exposed conditions, hazard class, etc.

Common Field Inspection Issues



Table 9.2.2.1(a) Maximum Distance Between Hangers (ft-in.)

	Nominal Pipe Size (in.)							
	¾	1	1¼	1½	2	2½	3	3½
Steel pipe except threaded lightwall	N/A	12-0	12-0	15-0	15-0	15-0	15-0	15-0
Threaded lightwall steel pipe	N/A	12-0	12-0	12-0	12-0	12-0	12-0	N/A
Copper tube	8-0	8-0	10-0	10-0	12-0	12-0	12-0	15-0
CPVC	5-6	6-0	6-6	7-0	8-0	9-0	10-0	N/A
Polybutylene (IPS)	N/A	3-9	4-7	5-0	5-11	N/A	N/A	N/A
Polybutylene (CTS)	2-11	3-4	3-11	4-5	5-5	N/A	N/A	N/A
Ductile iron pipe	N/A	N/A	N/A	N/A	N/A	N/A	15-0	N/A




Hangers must be listed to be used for CPVC

Common Field Inspection Issues

Standpipes on Roofs

- Fire Code: Where roof has slope less than 4 in 12, each standpipe shall be provided with a hose connection located either on roof or on the highest landing of stairway with stair access to roof.
- SCO allows final number on roof to be determined by local Fire Marshal. Stated as such in SCO guidelines.

Common Field Inspection Issues



Standpipes on roofs

Common Field Inspection Issues



Frozen and cracked
due to no automatic
drain valve

Common Field Inspection Issues



Provide sprinkler protection below floating ceilings. Also provide protection below anything over 4' wide.

NFPA 13 2007' 8.6.5.3.3

Obstructions



Obstructions

Distance from Sprinklers to Side of Obstruction: (A)	Maximum Allowable Distance of Deflector above Bottom of Obstruction (in.) (B)
Less than 1 ft	0
1 ft to less than 1 ft 6 in.	0
1 ft 6 in. to less than 2 ft	1
2 ft to less than 2 ft 6 in.	1
2 ft 6 in. to less than 3 ft	1
3 ft to less than 3 ft 6 in.	3
3 ft 6 in. to less than 4 ft	3
4 ft to less than 4 ft 6 in.	5
4 ft 6 in. to less than 5 ft	7
5 ft to less than 5 ft 6 in.	7
5 ft 6 in. to less than 6 ft	7
6 ft to less than 6 ft 6 in.	9
6 ft 6 in. to less than 7 ft	11
7 ft and greater	14

For SI units, 1 in. = 25.4 mm; 1 ft = 0.3048 m.
 Note: For (A) and (B), refer to Figure 8.10.6.1.2(a).





FIGURE 8.10.6.1.2(a) Position of Sprinklers to Avoid Obstructions to Discharge (Residential Upright and Pendent Spray Sprinklers).




A is to be 3'-0"


Obstructions



Obstructions



Common Field Inspection Issues



Good Jobs




Test isolation valve

Test drain valve

Preaction system

Good Jobs



Test connection

Drain stack

Pressure reducing valve

Factory set
Fire hose connection

Test connection

Good Jobs



Good Jobs



Good Jobs



Good Jobs

Notice painted bolts



Work performed by inmate labor.

Successful Fire Sprinkler Systems

Questions?

Robert Griffis

robert.griffis@doa.nc.gov

919-807-4118

<http://www.nc-sco.com/>