

# 42<sup>nd</sup> Annual State Construction Conference

March 2, 2023



**NC**★**DOA**  
Department of Administration  
**State Construction Office**

# Life Cycle Cost Analysis Update

## Pivoting Toward Sustainability



Tom Galdi, PE - SCO  
Thomas Vu, PE - AEI  
3/02/2023



# Recent NC Energy Directives

## Executive Order 80

*Increase Use of Clean Energy Technologies and Energy Efficient Measures*



2023 State Construction Conference

## House Bill 951

*Utilities to Take Reasonable Steps to Achieve Carbon Neutrality by 2050*



2022 State Construction Conference

# National and International Targets

## Paris Agreement and Executive Orders

- Power Sector 100% Carbon Free by 2035
- Net Zero Economy by 2050.

### PARIS CLIMATE AGREEMENT





# How to Emit Less Carbon




- Efficiency
- Lower GWP Refrigerants
- Electrification




# eGRID Emission Factors

CO<sub>2</sub> total output emission rate (lb/MWh)  
by eGRID subregion, 2020



Sort A to Z    Sort by Amount

US: 818.29 (lb/MWh)





# Report: Replacing coal plants with solar, wind is cheaper

BY CARLY WANNA  
Bloomberg

Replacing coal power plants across the United States with renewable energy projects would reduce carbon emissions and require less water.

It would also save money.

Nearly all existing U.S. coal plants require more cash to operate than the cost of replacing them with new wind or solar projects, according to a report published Monday by San Francisco-based climate think tank Energy Innovation.

The finding is in line with past research by BloombergNEF that determined building new solar and wind farms is cheaper than operating existing coal or gas power plants in much of the world.

energy in the U.S. is President Joe Biden's climate legislation, which provides billions of dollars in incentives for clean energy infrastructure.

"The Inflation Reduction Act has made this local replacement and reinvestment scenario so economic and so much cheaper than coal," said Michelle Solomon, a policy analyst at Energy Innovation and the lead author of the report. "It really creates a big opportunity to diversify the economics in coal communities."

The law includes a 10% tax credit for so-called "energy communities," including areas with retired coal plants, to transition to clean energy infrastructure.

The report's authors calculated the costs of operating each of 210 coal plants in the United

well as future maintenance expenditures. They then compared those numbers to costs associated with installing and operating new wind and solar projects nearby. In all but one case, the renewable project required less cash.

Energy Innovation has tracked the costs of new renewable projects in three Coal Cost Crossover reports since 2019. The first report found that running 62% of existing coal capacity in the U.S. cost more than producing the same amount of energy from renewable sources. That increased to 72% in the 2021 edition.

Now, incentives from the Inflation Reduction Act mean the share of coal power that's more expensive has risen to 99%.

The White House's push to move the U.S.

industry groups, as well as some members of Congress - like Democratic Sen. Joe Manchin of West Virginia - who have argued that the plans will strip jobs from communities that need them.

But even with renewables costing less overall, replacing the country's coal plants would require billions in investment, which the study authors say would create economic opportunity. Mike O'Boyle, an author of the report and a director at Energy Innovation, says he hopes the new research will encourage public utilities commissions to invest in renewable energy.

"Those regulators are some of the most important policymakers and actors in the energy transition," said O'Boyle. "Now they've got tools to take a proactive role."




# G.S. 143-64.10-15 Energy Policy and Life Cycle Cost Analysis

## HIGHLIGHTS

- The State shall take a leadership role in aggressively undertaking energy conservation in North Carolina.
- Facility Designs shall take into consideration the total Life Cycle Cost.
- Energy Consumption Analysis of the facilities 'Energy Consuming Systems'.





# LIFE CYCLE COST ANALYSIS

for

# STATE FACILITIES

October 1, 2001


State Construction Office  
Suite 450  
301 North Wilmington Street  
Raleigh, NC 27601-2827  
1.919.733.7962  
1.919.733.6609 FAX  
<http://interscope2.doa.state.nc.us/sco/main.htm>

- *“Since the passage of this legislation, the design of new state facilities in North Carolina has not undergone any significant improvement in quality as a result of life cycle costing. The primary reason for this appears to be that life cycle costing is treated as an “academic exercise”, rather than as a design element, by architects and engineers. The goal for this text is to help rectify this situation.”*




# 2<sup>nd</sup> Law of Thermodynamics

If the particles represent gas molecules at normal temperatures inside a closed container, which of the illustrated configurations came first?



If you tossed bricks off a truck, which kind of pile of bricks would you more likely produce?







# LCCA – Why Update

Due – 22 + years

SIR Results not Intuitive

Repetitive Analysis and Results

Shift Focus

# Existing LCC Data Sheets

**LIFE CYCLE COST ANALYSIS FOR STATE FACILITIES**

STATE CONSTRUCTION OFFICE  
N.C. DEPT. OF ADMINISTRATION  
RALEIGH, NORTH CAROLINA

DATA FOR ALTERNATIVE:

CONSTRUCTION YEAR:

ECONOMIC LIFE:  Years

INFLATION RATE:

CAPITAL INVESTMENT

CAPITAL:  \$

LOAN/BOND:

INTEREST RATE:  %

LOAN/BOND TERM:  Years

ANNUAL OPERATING COSTS AND CONSUMPTION

ELECTRICITY:  \$  KWH

NATURAL GAS:  \$  MCF

PROPANE:  \$  GAL

FUEL OIL:  \$  GAL

COAL:  \$  TONS

MAINTENANCE:  \$

NON-RECURRING REPAIR/REPLACEMENT COSTS

DESCRIPTION	YEAR	COST

**LIFE CYCLE COST ANALYSIS FOR STATE FACILITIES**

STATE CONSTRUCTION OFFICE  
N.C. DEPT. OF ADMINISTRATION  
RALEIGH, NORTH CAROLINA

YEAR	CAPITAL \$	ENERGY \$	MAINTENANCE \$	REPAIR/REPLACE \$	TOTAL COST
1	\$200,000	\$20,000	\$7,000	\$0	\$227,000
2	\$0	\$20,600	\$7,210	\$0	\$27,810
3	\$0	\$21,218	\$7,426	\$0	\$28,644
4	\$0	\$21,855	\$7,649	\$0	\$29,504
5	\$0	\$22,510	\$7,879	\$0	\$30,389
6	\$0	\$23,185	\$8,115	\$0	\$31,300
7	\$0	\$23,881	\$8,358	\$0	\$32,239
8	\$0	\$24,597	\$8,609	\$0	\$33,207
9	\$0	\$25,335	\$8,867	\$0	\$34,203
10	\$0	\$26,095	\$9,133	\$0	\$35,229
11	\$0	\$26,878	\$9,407	\$0	\$36,286
12	\$0	\$27,685	\$9,690	\$0	\$37,374
13	\$0	\$28,515	\$9,980	\$0	\$38,496
14	\$0	\$29,371	\$10,280	\$0	\$39,650
15	\$0	\$30,252	\$10,588	\$0	\$40,840
16	\$0	\$31,159	\$10,906	\$0	\$42,065
17	\$0	\$32,094	\$11,233	\$0	\$43,327
18	\$0	\$33,057	\$11,570	\$0	\$44,627
19	\$0	\$34,049	\$11,917	\$0	\$45,966
20	\$0	\$35,070	\$12,275	\$0	\$47,345
21	\$0	\$36,122	\$12,643	\$0	\$48,765
22	\$0	\$37,206	\$13,022	\$0	\$50,228
23	\$0	\$38,322	\$13,413	\$0	\$51,735
24	\$0	\$39,472	\$13,815	\$0	\$53,287
25	\$0	\$40,656	\$14,230	\$0	\$54,885
26	\$0	\$41,876	\$14,656	\$0	\$56,532
27	\$0	\$43,132	\$15,096	\$0	\$58,228
28	\$0	\$44,426	\$15,549	\$0	\$59,975
29	\$0	\$45,759	\$16,015	\$0	\$61,774
30	\$0	\$47,131	\$16,496	\$0	\$63,627
31	\$0	\$48,545	\$16,991	\$0	\$65,536
32	\$0	\$50,002	\$17,501	\$0	\$67,502
33	\$0	\$51,502	\$18,026	\$0	\$69,527
34	\$0	\$53,047	\$18,566	\$0	\$71,613
35	\$0	\$54,638	\$19,123	\$0	\$73,761
TOT.	\$200,000	\$1,209,242	\$423,235	\$0	
TOTAL LIFE CYCLE COST FOR ALTERNATIVE NO.0					\$1,832,476

# READING SIR SUMMARY SHEETS

(A) Alternative ID	(B) Life Cycle Investment Cost	(C) Life Cycle Operating Cost	(D) Increased Investment Cost	(E) Operating Cost Savings	(F) SIR	(G) Rank
A1.0	\$14,800	\$362,046	N/A	N/A	N/A	Base Case
A1.1	\$19,750	\$355,791	\$4,950	\$6,255	1.26	1
			\$0	\$0	0.00	2
			\$0	\$0	0.00	2
			\$0	\$0	0.00	2
			\$0	\$0	0.00	2
			\$0	\$0	0.00	2
			\$0	\$0	0.00	2
			\$0	\$0	0.00	2

(A) Alternative ID	(B) Life Cycle Investment Cost	(C) Life Cycle Operating Cost	(D) Increased Investment Cost	(E) Operating Cost Savings	(F) SIR	(G) Rank
P1-1	\$14,442	\$63,206	N/A	N/A	N/A	Base Case
P1-2	\$24,071	\$48,220	\$9,629	\$14,986	1.56	1
P1-3	\$12,837	\$30,757	-\$1,605	\$32,449	-20.22	9
			\$0	\$0	0.00	2
			\$0	\$0	0.00	2
			\$0	\$0	0.00	2
			\$0	\$0	0.00	2
			\$0	\$0	0.00	2
			\$0	\$0	0.00	2

This option is actually the lowest LCC

(A) Alternative ID	(B) Life Cycle Investment Cost	(C) Life Cycle Operating Cost	(D) Increased Investment Cost	(E) Operating Cost Savings	(F) SIR	(G) Rank
B0	\$840,000	\$2,151,348	N/A	N/A	N/A	Base Case
H-1	\$770,000	\$2,134,927	-\$70,000	\$16,421	-0.23	7
H-2	\$1,050,000	\$2,347,150	\$210,000	-\$195,802	-0.93	9
H-3	\$1,190,000	\$2,283,603	\$350,000	-\$132,255	-0.38	8
			\$0	\$0	0.00	1
			\$0	\$0	0.00	1
			\$0	\$0	0.00	1
			\$0	\$0	0.00	1



# Takeaways from Review of LCCA Reports



Repetition in  
Analysis

Lowest LCC  
not always  
selected

Energy  
Conservation  
not the focus

Trends  
Established

# Common Results



# Moving Forward



USER FRIENDLY  
INTUITIVE PROCESS



EASY TO COLLECT  
AND COMPILE  
ONGOING RESULTS.



MAKE RESULTS  
PUBLIC TO BE BUILT  
UPON.



FOCUS MORE ON  
ENERGY CONSUMING  
SYSTEMS.



JOIN PUSH TOWARD  
SUSTAINABILITY.






## Notable Updates

- Comparisons Approved by Owner at Contract Negotiation or Soon After.
- An Expectation of a Minimum Two LCC comparisons.
- HVAC System Comparison Required with One Option Sustainable (Not 'Business as Usual').



# Business as Usual




A photograph of the interior of a fusion reactor, likely the National Ignition Facility. The scene is dominated by a bright, multi-pointed starburst of blue light emanating from the center, illuminating the surrounding metallic structures and pipes. The lighting is a deep, vibrant blue, creating a high-tech, futuristic atmosphere. The reactor's complex machinery, including various pipes, valves, and structural beams, is visible in the foreground and background, all bathed in the same blue glow.

# Not Business as Usual?

- *“U.S. Achieves Fusion Energy Breakthrough”*



# Photovoltaic



# Life Cycle Costing toward Sustainability

## Heavy Timber Construction

- *Renewable and Recyclable*



## Metal Roofing

- *Recyclable*
- *30-50 year life*








## Life Cycle Costing toward Sustainability

DHHS Campus – Salvaged concrete from demolished parking lots used as sub-base.




# Daylighting



- Double-loaded core
- Skylights at deep floor plate
- Low-E glass, with sunshades and ceramic fritting

# HVRF (Hybrid VRF)




Coming in 2023

Less chance of installation problems


Avoids some upcoming restrictions on refrigerant in egress corridors and refrigerant monitoring requirements.

# Water Source Equipment

## Heat Recovery Chiller




## Heater




# Water Source Equipment

Same machine as HR chiller and Heater. No reversing valve. Internal controls determine mode.







# Air Source Heat Pumps

# DOE Cold Climate Heat Pump Challenge

## Performance Requirements

### Seasonal Heating

- 8.5 HSPF2 (ASHRAE Region V)
- Heating at 5°F [-15°C]
- Minimum COP of 2.1-2.4 at 5°F
- Capacity ratio of 100% for 5°F capacity to 47°F capacity
- Minimum turndown ratio at 47°F
- Compressor cut-in and cut-out temperatures

### Heating at -15°F [-26°C] (optional)

- HP operation at -15°F as measured by compressor cut-in and cut-out temperatures



# 2024 NCECC - 2021 ICC - ASHRAE 90.1-2019 - Includes Air to Water Heat Pumps

Equipment Type	Size Category Refrigerating Capacity Ton	Cooling-Operation Efficiency Air-Source (EER, FL/IPLV), Btu/W-hr		Heating Source Conditions OAT (db/wb) °F	Heat Pump Heating Full Load Efficiency (COPh), W/W			Test Procedure
		Path A	Path B		Entering/Leaving Heating Liquid Temperature			
					Low 95°F/105°F	Medium 105°F/120°F	High 120°F/140°F	

Per ASHRAE 90.1-2019 Addendum y (approved December 9, 2021)

Air-source	<150	≥9.595 FL ≥13.02 IPLV.IP	≥9.215 FL ≥15.01 IPLV.IP	47 db 43 wb	≥3.290	≥2.770	≥2.310	AHRI 550/590
				17 db 15 wb	≥2.029	≥1.775	≥1.483	
	>150	≥9.595 FL ≥13.30 IPLV.IP	≥9.215 FL ≥15.30 IPLV.IP	47 db 43 wb	≥3.290	≥2.770	≥2.310	
				17 db 15 wb	≥2.029	≥1.775	≥1.483	


Data shown from ASHRAE Standard 90.1-2019 Table 6.8.1-16 Addendum y

# More “Not Business As Usual” Equipment


## Air-Cooled Chiller with Heat Recovery



## Air-to-Water Heat Pump




## Air-to-Water Heat Pump with Heat Recovery







# Cold Climate Heat Pump



© 2020 Trane | 29


# Hot Water Supply Temperature

## What is needed by the zone equipment?



- Most equipment can be selected for space heating with 100°F to 110°F hot water

Equipment	Minimum Hot Water Supply Temperature
DOAS Air Handler	>80F
Central Air Handler/VAV	95-105F
Single Zone VAV AHU	100-105F
VAV boxes (4row)	95-105F
Fan Coil Units w/ Changeover coil	100-115F

# Hot Water Temperature Impacts



# Air Cooled Heat Pump Equipment






# Air Cooled Heat Pump Equipment


## Medium Building Application

- Single unit can replace chiller and boiler
- Includes back up




© 2022 Trans. All Rights Reserved. | 60

## System Configurations and Options Base System




I22 Trane | 59



Air cooled chiller






**Auxiliary heat**



- Conventional
- Condensing
- Electric
- or
- In-space electric

# Large Building – Heat Recovery



© 2022 Trans. All Rights Reserved. 1 72

*sources/sinks*  
**Exhaust Air Energy Recovery**





# How Tesla's Ingenious Heat Pump Gives It An Edge Over Other Electric Cars

Tesla's effective heat pump helps maximize the car's power in all weather conditions, making it a triumph card against other EVs.

BY MILICA CIKUSA PUBLISHED 7 DAYS AGO



2023 State Construction Conference

# LIFE CYCLE COST ANALYSIS

NC State Construction Office



Project Name: Sample Bldg

SCO ID: \_\_\_\_\_

Prepared By: \_\_\_\_\_

inflation rate 3.8 %  
discount rate 3.6 %

Adjustment Fctr 1.002

### OPTION 1 DESCRIPTION

DOAS w/Chilled water Cooling and HW heat.

### OPTION 2 DESCRIPTION

Doas similar to Option 1 but includes heat pipe heat recovery.

ECONOMIC LIFE 1 25 yrs

ECONOMIC LIFE 2 20 yrs

Analysis period 25 yrs

CAPITAL COST \$720,000

CAPITAL COST \$1,404,000

ENERGY COST \$554,554 /yr

ENERGY COST \$445,000 /yr

ANNUAL MAINT. /yr

ANNUAL MAINT. \$1,000 /yr

Life Cycle Cost \$14,909,825

Life Cycle Cost \$13,049,639

LCC Rank 2

LCC Rank 1

Payback 6.3 yrs



(Negative payback means lowest capital cost option has lowest annual costs also)

Comparison Summary, Results and Implementation:

The resulting LCCA compared DOAS HVAC system against a DOAS HVAC system with a Wrap Around system. A \$1000 annual maintenance contract is included with the heat pipe. The LCCA shows a payback period of 6.3 years during the 25 year analysis period. The heat pipe option will be implemented.

Professional Seal

# Heat Pipes



# Results Available for Public Use

Life Cycle Cost Analysis Summary of Evaluations									
SCO ID #	Owner	Eng/ Arch.	Project	Disc. A/M/E	Option 1 (Baseline)	Option 2 (Evaluated)	Payback (yrs)	Sel. (1 or 2)	
1 20-22343	NCSU	AEI	Int. Sci. Bldg.	A	Glazing - Solarban double pane	Glazing - Solarban triple pane	120.2	1	
2 20-22343	NCSU	AEI	Int. Sci. Bldg.	A	Roof - R30	Roof - R50	528.2	1	
3 20-22343	NCSU	AEI	Int. Sci. Bldg.	A	Wall - R21	Wall R-30	158	1	
4 20-22343	NCSU	AEI	Int. Sci. Bldg.	M	DOAS w/wrap around heat pipe	DOAS w/Konvecta High Performance Wrap System	8.2	2	
5									
6									
7									
8									
9									
10									
11									
12									
13									
14									
15									



# PV & Battery (Microgrid)

- United Therapeutics (RTP)
- Net-Zero cGMP Warehouse
- No OnSite Fossil Fuels
- Ballasted Rooftop Solar (563 kW)





# PV & Battery (Microgrid)

- Tesla Megapack ilo Diesel Generators
- Operate in 'Island Mode' without Utility Power
- 6.2 mWh / 1.54 kW Total Lithium Iron Phosphate (LFP) Battery
  - Assumed Zero PV Contribution
  - Assumed 8 Hour Fire Pump (Code) – 1,000 kWh
  - 24 Hour Full Facility – 2,724 kWh
  - 48 Hour Cold Storage – 1,586 kWh





# Heat Recovery Chillers




2023 State Construction Conference

- University of Virginia
- Conversion MTHW (230F) LTHW (170F)
- 1800-ton York CYK
- 42F Chilled Water
- 30 MMBH 170F Heating Hot Water
- 1.62 kW/Ton (COP=2.17)
- Reduces utility costs by over \$1M per year and eliminates 20k metric tons of CO2 emissions per year



# Retrofits - Going All Electric Heating

## STEP 4 Hill & Haynes: ENERGY USAGE ⓘ


Phase



**Option 1 - Like for Like** Total NG Demand (mmBTU)



  **3,641**

Option 1 - Total Energy Consumed (MBH)


 Air Cooled Chillers (kWh) **6,013,013**

**972,405**


**Option 2 - HRC'S** Boiler Usage (kWh)

  **61,394**

HRC Usage (kWh)


 **209,769**

Option 2 - Total Energy Consumed (MBH)


 Air Cooled Chillers (kWh) **780,118**

**3,584,868**


**Option 3 - ASHP'S** Air Source Heat Pump (kWh)

 **18,127**

HRC Usage (kWh)

 **209,770**

Option 3 - Total Energy Consumed (MBH)

 Option 3 - Total (kWh) **780,117**

**3,437,329**



# Retrofits - Going All Electric Heating

STEP 5 Hill & Haynes: **LCCA TOOL**



RESET - AEI ESTIMATES



REMOVE ACC CREDIT



Option 1 - First Cost

Option 2 - First Cost

Option 3 - First Cost

Electricity Cost (\$/kWh)

Natural Gas Rate (\$/kCFH)

**Option 1**  
Like for Like

First Cost	Annual Energy Cost	Life Cycle Cost
\$670,000	\$119,499	\$6,039,013

**Option 2**  
HRC

First Cost	Annual Energy Cost	Life Cycle Cost
\$1,730,000	\$92,513	\$5,886,550

**Option 3**  
ASHP'S

First Cost	Annual Energy Cost	Life Cycle Cost
\$1,150,000	\$88,705	\$5,135,483

Electrical Escalation:

Natural Gas Escalation:

Discount Rate (Nominal):


Comparison Time Frame:



# Enhanced Energy Recovery

- NC State Plant Science Building
- Enhanced Energy Recovery Loop & Skid


Results energy calculations:	without ERS	with ERS	nr of hours	nr of hours with external heat/cold
<b>Reduction of heating energy: 97%</b>				
<b>Reduction of cooling energy: 19%</b>				
	(MMBtu)	(MMBtu)	(h)	(h)
heating requirement	13'223.6	269.7	7'968	864
including reheating after dehumidifying	(6'726.5)	(16.5)	(4'699)	(209)
cooling requirement	30'185.8	24'166.3	5'491	5'491



2023 State Construction Conference




# Enhanced Energy Recovery





# Ground-Source Heat Pumps

- City of Durham Mist Lake Facility (171k gsf)
- 500-ton ground-source heat pump
- 500 ft. deep bores, 180 bores total.
- \$50k annual cost savings over 50 years





# De-Coupled HVAC Systems



20-30% energy savings compared to all-air VAV reheat systems

# Active Chilled Beams



2023 St



# Passive Chilled Beams



2023 State Construction Conference



# Radiant Ceiling Panels



2023 State Construction Conference





# Radiant Floors



2023 State Construction Conference



# Passive Strategies

- Ryerson Education Facility (16k gsf, Lake County, IL)
- PHIUS Zero 2021
- Super insulated and ultra-airtight building envelope
- Downsized mechanical equipment
- R-90 Roof
- R-60 Walls
- Glazing Assembly U-value: 0.138





# Equipment Bidding – G.S. 143-64.12

- *“The Department of Administration shall develop and implement policies, procedures, and standards to ensure that state purchasing practices improve energy efficiency and take the cost of the product over the economic life of the product into consideration”. (Life Cycle Bidding is not specifically required)*

# Chiller LCC Bidding

BID DATA FORM - ATTACH TO FORM OF PROPOSAL

CHILLERS 200 TONS & LARGER					
<b>PROJECT OWNER:</b> .....					
<b>PROJECT TITLE:</b> .....					
<b>SCO ID #:</b> .....					
<b>Electricity Cost \$/kwh</b> _____					
<b>Life Cycle (yrs)</b> _____					
<b>Designer Data</b>					
Chiller Utilization Profile					
Load %	Load (tons)	Hours per Year	Entering <sup>1</sup> Cond. Water (deg F)	Leaving <sup>1</sup> Cond. Water (deg F)	Outdoor Air Dry Bulb <sup>2</sup> (deg F)
100		88	85	95	95
75		3679	75	85	80
50		3942	65	75	65
25		1051	65	75	55
Note 1: Leave blank for air cooled chillers.					
Note 2: Dry bulb temperature for air cooled chillers.					
<b>Vendor Data</b>					
Base Bid Chiller Performance					
Alternate number	Alt # M - 1A	Alt # M - 1B	Alt # M - 1C	Alt # M - 1D	
Manufacturer Name	Manuf. 1	Manuf. 2	Manuf. 3	Manuf. 4	
Model Number					
Input KW @ 100 % Load					
Input KW @ 75 % Load					
Input KW @ 50 % Load					
Input KW @ 25 % Load					
Bid Price (\$)					
<b>Calculation</b>					
1st year energy (\$)	\$0	\$0	\$0	\$0	\$0
Life Cycle Cost	\$0	\$0	\$0	\$0	\$0
<b>Vendor Data</b>					
Higher Eff. Preferred Alternate Chiller Performance					
Alternate number	Alt # M - 2A	Alt # M - 2B	Alt # M - 2C	Alt # M - 2D	
Manufacturer Name	Manuf. 1	Manuf. 2	Manuf. 3	Manuf. 4	
Style					
Model Number					
Input KW @ 100 % Load					
Input KW @ 75 % Load					
Input KW @ 50 % Load					
Input KW @ 25 % Load					
Bid Price (\$)					
<b>Calculation</b>					
1st year energy (\$)	\$0	\$0	\$0	\$0	\$0
Life Cycle Cost	\$0	\$0	\$0	\$0	\$0

Can Bid a second chiller type





# Cooling Tower LCC Bidding

BID DATA FORM - ATTACH TO FORM OF PROPOSAL


COOLING TOWERS 200 TONS & LARGER					
PROJECT OWNER: _____					
PROJECT TITLE: _____					
SCO ID #: _____					
Electricity Cost \$/kwh _____					
Life Cycle (yrs) _____					
Range EWT-LWT (F) _____					
<b>Designer Data</b>					
Cooling Tower Utilization Profile					
Load %	Load (tons)	Flow (GPM)	Hours Per Year <sup>1</sup>	Leaving Water (deg F) <sup>1</sup>	Outdoor Air Wet Bulb (deg F) <sup>1</sup>
100			88	85	78
75			3679	75	66
50			3942	65	54
25			1051	65	46
<b>Vendor Data</b>					
Cooling Tower Performance					
Alternate number	Alt # M - 3A	Alt # M - 3B	Alt # M - 3C	Alt # M - 3D	
Manufacturer Name	Manuf. 1	Manuf. 2	Manuf. 3	Manuf. 4	
Dimensions LxWxH					
Model Number					
Input KW @ 100 % Load					
Input KW @ 75 % Load					
Input KW @ 50 % Load					
Input KW @ 25 % Load					
Vertical Tower Lift (ft)					
Spray Nozzle Pres. (ft) <sup>2</sup>					
First Cost (\$)					
<b>Calculation</b>					
Tower Energy Cost (\$)	\$0	\$0	\$0	\$0	
Tower Pumping Cost (\$)	\$0	\$0	\$0	\$0	
Total Life Cycle Cost (\$)	\$0	\$0	\$0	\$0	

Default Data is Provided

Pump Energy is now Taken into Account.



<https://ncadmin.nc.gov/businesses/state-construction/forms-and-documents#design-review>



# THE END

Questions?

[tom.galdi@doa.nc.gov](mailto:tom.galdi@doa.nc.gov)

